

WATERSTOP PRODUCT CO.,LTD.

REPORT NO.PD-003/09

TEST REPORT FOR WATER FORM OIL

Introduction

A sample of WATER FORM OIL was submitted by Waterstop Product Co.,Ltd. For analysis and testing as a mould release agent.

The product was applied in accordance with the manufacturers instructions and below is a summary of the results achieved:-


Type Liquid
APPERRANCE/FORM: Brown
SPECIFIC GRAVITY: 0.86 kg. / litre
CHEMICAL BASE: based oil

16 samples of concrete were caste in moulds 15 cm. X 15 cm. Having applied WATER FORM OIL At the recommended coverage rate to the steel moulds after 24 hours the moulds were stripped and examined for cement paste build up. No significant cement paste was evident The concrete was examined for staining or surface damage again none was evident.

Conclusion

WATER FORM OIL when applied in accordance with the manufacturers instructions acts as very acceptable mould oil and passes the requirements for such material

PREPARAED BY :


Chansa Wongwattana
Factory Manager
September 14/2009

